



EC - CERTIFICATE

Type-Examination No: CE 67603 Issue No. 2



Category, make and type or trade name: S100 Slam Shut Valves
As per technical file S100 issue 0

Name and address of manufacturer: Elster Jeavons Limited
Lower Church Lane
Tipton
West Midlands
DY4 7PH

Name and address of Certificate holder: -


Date of submission for EEC type-examination: 17 December 2001

Certificate issued on the basis of the following requirement: On the basis of our examination under the requirements of Council Directive 97/23/EC Module B the Pressure Equipment Directive, as transposed into UK law by the Pressure Equipment Regulations SI 1999 2001,

Date of type-examination: 26 June 2002

Documents bearing the type examination number shown above are annexed to this Certificate:

For and on behalf of the BRITISH STANDARDS INSTITUTION,
Notified Body Number 0086

Signature:  A Boyd (General Manager)

Date: 09 July 2002

Any modification to the design of this product will invalidate this EC-Certificate and the BSI Notified Body Number 0086 must be informed without delay

Prepared by: BSI Product Services Maylands Avenue Hemel Hempstead
Hertfordshire HP2 4SQ UK Telephone: 44 1442 230442 Fax: 44 1442 231442



EC - CERTIFICATE

Type-Examination No: CE 67603 Issue No. 2



(Continuation Sheet)

ADDITIONAL INFORMATION

LIMITATIONS OF CERTIFICATE VALIDITY

TS = -20 to +80°C

PS = 0 to 16 bar g for 2" NP16, 3" NP16 and 4" NP16.
PS = 0 to 19 bar g for 2" ANSI, 3" ANSI and 4" ANSI.

For and on behalf of the BRITISH STANDARDS INSTITUTION,
Notified Body Number 0086

Signature:  A Boyd (General Manager)
PI

Date: 09 July 2002

Any modification to the design of this product will invalidate this EC-Certificate and the BSI Notified Body Number 0086 must be informed without delay

Prepared by: BSI Product Services Maylands Avenue Hemel Hempstead
Hertfordshire HP2 4SQ UK Telephone: 44 1442 230442 Fax: 44 1442 231442