



Type Examination

No. CE 67603 Issue 3

Issued to:

Elster Jeavons Limited
Lower Church Lane
Tipton
West Midlands
DY4 7PH
United Kingdom



In respect of:

S100 & S300 Slam Shut Valves as per technical file S100/S300 issue 0

On the basis of our examination under the requirements of Council Directive 97/23/EC Module B of the Pressure Equipment Directive, as transposed into UK law by the Pressure Equipment Regulations SI 1999 2001.

For and on behalf of the British Standards Institution, a Notified Body for the above Directive (Notified Body Number 0086):

Alastair Trivett, Managing Director, BSI Product Services – Global

First Issued: 9 Jul 2002

Date: 21 Dec 2006

Page: 1 of 2

Any modifications to the design of this product will invalidate this EC-Type Examination Certificate and the BSI Notified Body, Number 0086 must be informed without delay

Type Examination

No: CE 67603 Issue 3

ADDITIONAL INFORMATION

LIMITATIONS OF CERTIFICATE VALIDITY

S100 models

TS = -20 to +80°C

PS = 0 to 16 bar g for 2" NP16, 3" NP16 and 4" NP16.

PS = 0 to 19 bar g for 2" ANSI, 3" ANSI and 4" ANSI.

S300 models

TS = -20 to + 80 °C

PS = 0 to 20 bar g for ¾", 1" & 2" models

First Issued: 9 Jul 2002

Date: 21 Dec 2006

Page: 2 of 2

Any modifications to the design of this product will invalidate this EC-Type Certificate and the BSI Notified Body, Number 0086 must be informed without delay